



Is the location accessible

NO

Maintenance free terminals required



Is there a suitable fixing position

NO

Cable clamping recommended



Traditional Junction Boxes are acceptable

YES

Description	N° of Terminals	Terminal Rating	Reference	Benefits / Considerations
Downlighter Junction Box	3 x 3 x 1.5mm <sup>2</sup> 1 x 2 x 1.5mm <sup>2</sup>	16A	<b>J501</b>	Provided with cable clamps and separate terminals for flex
Maintenance Free Junction Box	3 x 4 x (0.5-4.0mm <sup>2</sup> )	32A	<b>J803</b>	Suitable for use in inaccessible locations
	4 x 4 x (0.5 - 4.0mm <sup>2</sup> )	20A	<b>J804</b>	
Traditional Junction Boxes	4	20A	<b>J201</b>	Acceptable for locations which are accessible
	4	20A	<b>J301</b>	
	3	30A	<b>J401</b>	
	6	20A	<b>J601</b>	

Junction Boxes